

2023 CONSUMER CONFIDENCE REPORT

Board of Directors

Andy Zody

President

Luanne Uhl

Vice President

Kellie Williams

Secretary / Treasurer

Pastor Eric York

Director

David Nilsen

Director

Staff**Joseph Tapia**

General Manager

Mike Siaz

Field Supervisor

Joseph Zuniga

Water Maintenance

Nathan Havrilo

Water Maintenance

April Chaplin

Accounts Payable

Christina Garland

Accounts Receivable

Paul Pollard

Water Quality

Therese Rodriguez

Manager's Assistant

Contact**Information**

P.O. Box 291820

Phelan, CA 92329

4200 Sunnyslope Rd

Phelan, CA 92371

(760) 868-3755 main

(760) 868-2174 fax

Office Email:

sheepcreek@verizon.net

Visit us online at:

www.sheepcreekwater.com**After Hours**

For after hours

emergencies, call:

(760) 553-6023

Questions

This report has been compiled by Paul Pollard, Water Quality Tech.

For more information about this report, or for questions relating to your drinking water, please call our office at (760) 868-3755.

Dear Shareholders & Customers

Sheep Creek Water Company is once again proud to present our Annual Water Quality Report. This report covers all testing performed between January 1, 2023 and December 31, 2023. You will find information regarding drinking water quality, the source of your water and other information in compliance with state and federal standards. Your interest in the company is overseen by a five-member Board of Directors. The Board of Directors currently meet on the third Tuesday of the month, at 6:00 pm. The agenda can be found online:

<https://www.sheepcreekwater.com/board-meeting-agendas>

Where Does My Water Come From?

Sheep Creek Water Company customers receive most of their drinking water from Sheep Creek Canyon below Wrightwood. All the water Sheep Creek produces is Ground Water only. Sheep Creek's gravity flow tunnel is producing 187 GPM as of December 31, 2023. The Company's remaining source of water comes from five wells located in the Sheep Creek Wash and one well located north of Smoke Tree Rd. With our system being gravity flow, this eliminates the need for booster stations and keeps our electricity cost down. The Company also has a connection with the Phelan Pinon Hills Community Service District. In 2023, 174,673,400 million gallons of water was produced, with July 12th being the max day of production at 968,520 gallons during a 24 hour time period. The company has a total of 7 storage reservoirs with a combined storage capacity of 6.1 million gallons. With this storage we are capable of maintaining positive pressure throughout the system during high demands and power outages. There are a total of 45 pressure reducing stations in 8 pressure zones supplying an average of 1202 active services.

Source Capacity Development

The State Water Resources Control Board Division of Drinking Water received a Corrective Action Plan Amendment (CAP-amendment) dated August 26, 2022, along with an updated, estimated timeline from Sheep Creek Water Company (SCWC) requesting a two-year extension for Compliance Order NO. 05-13-18R002, and a partial lift on the moratorium to request a Will-Serve Letter for 30 new meters.

The Division has reviewed and hereby accepts the CAP-amendment. The CAP-amendment and timeline allow completion of well # 13 by December 1, 2025, with additional sources planned if necessary. Extending the compliance deadline in the order is unnecessary at this time. SCWC should start making progress as soon as possible on complying with source capacity requirements as described in Section 64554 of the Title 22.

In addition, to further assist SCWC with self-management of its water production and water usage, until further notice, the Division suspends the service connection limitation imposed by Directive 1 in the Compliance Order No. 05-13-18R-002A1.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife. **Inorganic contaminants**, such as salts and metals, that can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharge, oil and gas production, mining or farming.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban storm runoff and residential uses. **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial process and petroleum production, and can also come from gas stations, urban storm water runoff, agriculture application and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production, and mining activities.

Source Water Assessment

A Source Water Assessment (SWA) was conducted for our sources in March 2001 and a SWA was conducted for Well 2A in May 2012. A new SWA was conducted for Well 11 in October 2018. A copy of the SWA is available to view at the Sheep Creek Water Company Office or at the SWRCB, DDW San Bernardino District office 464 West 4th St Suite 437. This plan is an assessment of the delineated area around our listed sources through which contaminants, if present, could migrate and reach our source of water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resource Control Board, Division of Drinking Water (SWRCB, DDW) prescribe regulations that limit the amount of certain contaminants in water provided by the Water Company. SWRCB, DDW regulations also establish limits for contaminants in bottled water that provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hot-line (1-800-426-4791).

Noticia Importante

Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo o hable con alguien que lo entienda bien.

Water Conservation & Allotment

Sheep Creek Water Company has experienced several years of low water levels and production due to years of drought conditions. Water Conservation Measures will remain in effect, **check all irrigation, faucets, toilets and swamp coolers for leaks and make repairs as necessary.** As of this time the current allotment remains at **750 cubic feet** for the first share and **150 cubic feet** for the remaining shares on Tier 1 and an additional 150 cubic feet per share for Tier 2. Long term goals for the company are to develop additional wells spread throughout the water district.

The Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants may be particularly at risk for infection. These people should seek advice about drinking water from their health care providers. The USEPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA Safe Drinking Water Hot-line at (800) 426-4791.

How Pure Should Our Water Be

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hot-line at: 1-800-426-4791

Lead and Copper Monitoring

SCWC monitors drinking water for specific contaminants on a regular basis. Lead and Copper sampling was completed during the month of August 2022. See below for 2022 results.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hot-line at (800) 426-4791 or www.epa.gov/safewater/lead.

Nitrate in Drinking Water

Nitrate in drinking water at levels above 45 ppm is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 45 ppm may also affect the ability for the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from you health care provider. Nitrate levels may rise for short periods of time due to rainfall or agricultural activity.

Sampling Results

During the past year, weekly water samples were collected in order to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state allows us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

PRIMARY SUBSTANCES						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AVERAGE DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Fluoride (mg/L)	2023	2	0.1	0.21	0.21	Erosion of natural deposits
Hexavalent Chromium (+6) (ug/L)	2020	50	0.02	2	14-ND	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Total Chromium (Cr) (ug/L)	2023	50	100	27	27	

Stage 2 - Disinfection Byproducts Rule (DBPR)						
Samples are collected at the lowest portion of the distribution system SS# 7 Johnson Rd north of Goss Rd						
Haloacetic Acids (ug/L)	2023	60	NA	ND	ND	By-product of drinking water disinfection
TTHMs [Total	2023	80	1	ND	ND	
Trihalomethanes] (ug/L)						

LEAD & COPPER TAP MONITORING						
Tap water samples were collected for lead and copper analyses from sample sites throughout the community PHG AMOUNT SITES ABOVE						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	ACTION LEVEL (AL)	PHG (MCLG) [MRDLG]	DETECTED (90TH%TILE)	AL/TOTAL SITES	TYPICAL SOURCE
Copper (mg/L)	Aug-22	1.3	0.3	0.2	0/20	Internal corrosion of household plumbing systems; erosion of natural deposits
Lead (mg/L)	Aug-22	0.015	0.005	ND	0/20	

SECONDARY SUBSTANCES						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AVERAGE DETECTED	RANGE LOW- HIGH	TYPICAL SOURCE
Chloride (mg/L)	2023	500	None	2.1	2.2	Runoff/leaching of natural deposits; seawater influence
Manganese (mg/L)	2023	0.50	None	0.036		Runoff from natural deposits
Sulfate (mg/L)	2023	500	None	130	130	Natural deposits; industrial waste
Total Dissolved Solids [TDS] (mg/L)	2023	1000	None	320	320	Runoff /leaching from natural deposits
Iron (mg/L)*	2023	300	None	1500	1500	Leaching from natural deposits; industrial wastes

RADIOLOGICAL						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AVERAGE DETECTED	TYPICAL SOURCE	
Gross Alpha (pCi/L)	2022	15	3	4.1	Erosion of natural deposits	

PHYSICAL						
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG) [MRDLG]	AVERAGE DETECTED	TYPICAL SOURCE	
PH	2023	None		7.9		
Odor (TON)	2023	3		1	Naturally-occurring organic material	
Color (Units)*	2023	15		20		
Turbidity (NTU)*	2023	5	0.1	5.8	Soil runoff	
Conductivity (µmhos/cm)	2023	900		460	Soil runoff	

MICROBIOLOGICAL						
SUBSTANCE UNIT OF MEASURE)	SAMPLES TAKEN	SAMPLES POSITIVE	MCL	TYPICAL SOURCE		
Total Coliform Bacteria (% positive)	156	0	>5 0% positive	Naturally present in the environment		

Definitions

AL (Action Level): No MCL for lead.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs (SMCLs) are set to protect the odor, taste and appearance of drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants

MRDLG (Maximum Residual Disinfectant Level Goal): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Milligrams per Liter (mg/L): The same as ppm or parts per million. This is equivalent to one inch in 16 miles.

Micrograms per Liter (ug/L): The same as ppb or parts per billion. This is equivalent to one inch in 16,000 miles.

NTU (Nephelometric Turbidity Unit): Unit for expressing cloudiness (turbidity) of a sample as measured by a turbidimeter.

ND (Not Detected): Indicates the substance was not found by laboratory analysis.

PDWS (Primary Drinking Water Standard): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health.

Water Treatment Process

Chlorine is added to the water as a precaution against any bacteria that may be present. We monitor chlorine levels daily, adding the lowest quantity necessary to protect the safety of your water, without compromising taste.

Water conservation doesn't have to inconvenience our lives to be effective. Simple changes in how we do our daily tasks can have a tremendous impact on our water usage. A little effort can save a lot of water.

MINERAL

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	PHG (MCLG)	RANGE DETECTED
Alkalinity (mg/L)	2023	None	None	110
Bicarbonate (mg/L)	2023	None	None	120-400
Calcium (mg/L)	2023	None	None	43
Magnesium (mg/L)	2023	None	None	9.3
Potassium (mg/L)	2023	None	None	4.1
Sodium (mg/L)	2023	None	None	43

Sheep Creek's average hardness- Well Site- 35 grains / Well 11- 8 grains

Sheep Creek Water Company is in compliance with all SWRCB, DDW sample requirements.